

REGIONAL WATER TESTING LAB, SAS NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
mdlsasnagar@gmail.com



TC-12772

TEST REPORT			
Name & Address of Customer : Noble Heart School Shivalik Vihar, Block-D, opp. Police Station Naya Gaon, MOhali, Punjab		Customer Reference No.	No : Ref No . NHS/24/15 Dated : 17/05/2024
		Sample Submitted by	Deepak
		Date of Sample Receipt	17/05/2024
		Analysis Starting Date	18/05/2024
		Analysis completion Date	23/05/2024
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC12772240000067F	Sample Type :	Treated Water
Test Report No.:	RWTLAS/2425/00044	Date of Issue :	27/05/2024
Registration no.:	RWTLAS/REG2425/00206	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	750 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Ground Floor,Near Wash room (Water Cooler) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	SAS Nagar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.86@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	184	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.23	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	160	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	220	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	54.51	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	20.41	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	60	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Manik Kataria
Sr. Chemist
Authorized Signatory
For,Regional Water Testing Lab
SAS Nagar

Principal
NOBLE HEART SCHOOL

----- End of the Test Report -----

PRESIDENT
NOBLE SOUL EDUCATIONAL SOCIETY
Shivalik Vihar Block-D,
Nayagaon, S.A.S. Nagar (Mohali)

REGIONAL WATER TESTING LAB, SAS NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab

mdlsasnagar@gmail.com

TEST REPORT


Name & Address of Customer : Noble Heart School Shivalik Vihar, Block-D, opp. Police Station Naya Gaon, MOhall, Punjab		Customer Reference No.	No : Ref No . NHS/24/15 Dated : 17/05/2024	
		Sample Submitted by	Deepak	
		Date of Sample Receipt	17/05/2024	
		Analysis Starting Date	18/05/2024	
		Analysis completion Date	23/05/2024	
Discipline : Bacteriological Testing		Group: Water		
ULR No.:		Sample Type :	Treated Water	
Test Report No.:	RWTLAS/2425/00044	Date of Issue :	27/05/2024	
Registration no.:	RWTLAS/REG2425/00206	Condition of Sample :	Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	750 ml / Amber Colored Glass Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Ground Floor,Near Wash room (Water Cooler) / NA	
Village :	Not Mentioned	Habitation :	Not Mentioned	
Block:	Not Mentioned	District :	SAS Nagar	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Manik Kataria
Sr. Chemist
Authorized Signatory
For,Regional Water Testing Lab
SAS Nagar



Principal
NOBLE HEART SCHOOL

End of the Test Report

President
NOBLE SOUL EDUCATIONAL SOCIETY
Shivalik Vihar Block-D,
Nayagaon, S.A.S. Nagar (Mohali)

Ph. 0172:-2786186, 5071152

ਦਫ਼ਤਰ ਮਿਊਂਸਿਪਲ ਕੌਂਸਲ, ਨਵਾਂ ਗਾਉਂ।

(ਜਿਲ੍ਹਾ-ਐਸ.ਏ.ਐਸ.ਨਗਰ)

Municipal Council Naya Gaon.


(Distt, S.A.S, Nagar)

ਨੰ: 281


ਮਿਤੀ: 14/06/2024

ਸਰਟੀਫਿਕੇਟ

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਨੋਬਲ ਹਾਰਟ ਸਕੂਲ, ਸ਼ਿਵਾਲਿਕ ਵਿਹਾਰ ਬਲਾਕ-ਡੀ, ਨਵਾਂ ਗਾਉਂ ਤਹਿਸੀਲ ਖਰੜ, ਜਿਲ੍ਹਾ ਐਸ.ਏ.ਐਸ.ਨਗਰ ਵਿਖੇ ਚੈਕਿੰਗ ਦੌਰਾਨ ਸਫ਼ਾਈ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਦਰੁੱਸਤ ਪਾਇਆ ਗਿਆ ਹੈ।


ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ,
ਨਗਰ ਕੌਂਸਲ, ਨਵਾਂ ਗਾਉਂ।


Principal
NOBLE HEART SCHOOL


PRESIDENT
NOBLE SOUL EDUCATIONAL SOCIETY
Shivalik Vihar Block-D,
Nayagaon, S.A.S. Nagar (Mohali)

Mail id.eonpnayagaon@ymail.com

Ph.0172-2786186,5071152

Municipal Council Naya Gaon

(Distt. S.A.S.Nagar)

Letter no:.....²⁸¹.....

Date:..14/6/2024

CERTIFICATE

Regarding Sanitation Condition of School

It is certified that an Inspection by Sanitation team from Municipal Council Naya Gaon S.A.S Nagar inspected the NOBLE HEART SCHOOL NAYA GAON on Dated 18-04-2024 Noble Heart School Naya Gaon has maintaining the hygienic sanitation condition in the school building & the Campus as per the norms prescribed by the central/State/U.T Govt.

The above certificate valid for a period of 31-03-2025.


Executive Officer,
Municipal Council Nayagaon.